

# Operating Records of Nuclear Power Plants in June

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	720	100.0	794,232	100.3	Shutdown due to periodic inspection. (14. Jun.-)
Tsuruga-1	BWR	357	312	43.3	103,932	40.4	
Tsuruga-2	PWR	1160	720	100.0	858,918	102.8	
Tomari-1	PWR	579	299	41.5	156,520	37.5	Shutdown due to periodic inspection. (25. Apr.-18. Jun.)
Tomari-2	PWR	579	720	100.0	427,708	102.6	
Onagawa-1	BWR	524	0	0.0	0	0.0	Shutdown due to periodic inspection. (8. Sep. 2002-)
Onagawa-2	BWR	825	0	0.0	0	0.0	Shutdown due to periodic inspection. (22. May-)
Onagawa-3	BWR	825	720	100.0	612,029	103.0	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002-)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar.-)
Fukushima I-3	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (18. Jul. 2002-)
Fukushima I-4	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (2. Dec. 2002-)
Fukushima I-5	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (11. Feb.-)
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Planned shutdown. (15. Apr.-)
Fukushima II-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (7. Jan.-)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr.-)
Fukushima II-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Dec. 2002-)
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb.-)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002-)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar.-)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002-)
Kashiwazaki Kariwa-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (7. Jan.-)
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Mar.-)
Kashiwazaki Kariwa-6	ABWR	1356	720	100.0	976,320	100.0	
Kashiwazaki Kariwa-7	ABWR	1356	246	34.2	294,434	30.2	Planned shutdown. (29. Mar.-20. Jun.)
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002-)
Hamaoka-2	BWR	840	720	100.0	604,104	99.9	
Hamaoka-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Feb.-)
Hamaoka-4	BWR	1137	0	0.0	0	0.0	Shutdown due to periodic inspection. (4. Sep. 2002-)
Shika-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Apr.-)
Mihama-1	PWR	340	720	100.0	249,993	102.1	Shutdown due to periodic inspection. (8. May.-19. Jun.)
Mihama-2	PWR	500	720	100.0	360,630	100.2	
Mihama-3	PWR	826	270	37.5	203,936	34.3	
Takahama-1	PWR	826	720	100.0	622,208	104.6	Shutdown due to periodic inspection. (28. Apr.-17. Jun.)
Takahama-2	PWR	826	720	100.0	616,374	103.6	
Takahama-3	PWR	870	720	100.0	649,420	103.7	
Takahama-4	PWR	870	334	46.4	279,410	44.6	Shutdown due to periodic inspection. (28. Apr.-17. Jun.)
Ohi-1	PWR	1175	634	88.0	723,343	85.5	Shutdown due to periodic inspection. (14. Apr.-4. Jun.)
Ohi-2	PWR	1175	720	100.0	859,122	101.6	
Ohi-3	PWR	1180	720	100.0	865,756	101.9	
Ohi-4	PWR	1180	288	40.0	343,441	40.4	Shutdown due to periodic inspection. (13. Jun.-)
Shimane-1	BWR	460	720	100.0	331,201	100.0	Shutdown due to periodic inspection. (15. Apr.-)
Shimane-2	BWR	820	0	0.0	0	0.0	
Ikata-1	PWR	566	0	0.0	0	0.0	Shutdown due to periodic inspection. (27. Apr.-)
Ikata-2	PWR	566	720	100.0	414,497	101.7	
Ikata-3	PWR	890	720	100.0	669,446	104.5	
Genkai-1	PWR	559	720	100.0	411,026	102.1	Shutdown due to periodic inspection. (20. Apr.-17. Jun.)
Genkai-2	PWR	559	720	100.0	414,859	103.1	
Genkai-3	PWR	1180	720	100.0	867,684	102.1	
Genkai-4	PWR	1180	720	100.0	860,455	101.3	
Sendai-1	PWR	890	319	44.3	225,326	35.2	
Sendai-2	PWR	890	720	100.0	647,307	101.0	
Total/Average (Previous Month)		45742 (45907)	17,822 (17,518)	47.6% (45.3)	15,443,631 (14,885,337)	46.9% (43.7)	