

# Operating Records of Nuclear Power Plants in September

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	720	100.0	789,060	99.6	Shutdown due to periodic inspection. (5. Sep.-)
Tsuruga-1	BWR	357	720	100.0	258,263	100.5	
Tsuruga-2	PWR	1160	96	13.3	107,146	12.8	
Tomari-1	PWR	579	720	100.0	421,547	101.1	Manual shutdown due to leakage in a regenerative heat exchanger room. (10. Sep.-)
Tomari-2	PWR	579	240	33.3	139,137	33.4	
Onagawa-1	BWR	524	720	100.0	379,272	100.5	Shutdown due to periodic inspection. (22. May.-)
Onagawa-2	BWR	825	0	0.0	0	0.0	
Onagawa-3	BWR	825	720	100.0	613,534	103.3	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002.-)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar.-)
Fukushima I-3	BWR	784	720	100.0	564,480	100.0	
Fukushima I-4	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (2. Dec. 2002.-)
Fukushima I-5	BWR	784	463	64.3	344,281	61.0	Shutdown due to periodic inspection. (11. Feb.-12. Sep.)
Fukushima I-6	BWR	1100	696	96.7	759,440	95.9	Shutdown due to periodic inspection. (30. Sep.-)
Fukushima II-1	BWR	1100	720	100.0	784,512	99.1	
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr.-)
Fukushima II-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Dec. 2002.-)
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb.-)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002.-)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar.-)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002.-)
Kashiwazaki Kariwa-4	BWR	1100	720	100.0	799,590	101.0	
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Mar.-)
Kashiwazaki Kariwa-6	ABWR	1356	720	100.0	1,001,948	102.6	
Kashiwazaki Kariwa-7	ABWR	1356	528	73.3	721,100	73.9	Shutdown due to periodic inspection. (23. Sep.-)
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002.-)
Hamaoka-2	BWR	840	720	100.0	599,557	99.1	
Hamaoka-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Feb.-)
Hamaoka-4	BWR	1137	720	100.0	818,116	99.9	
Shika-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Apr.-)
Mihama-1	PWR	340	720	100.0	245,803	100.4	Shutdown due to periodic inspection. (12. Sep.-)
Mihama-2	PWR	500	265	36.8	128,379	35.7	
Mihama-3	PWR	826	720	100.0	602,500	101.3	
Takahama-1	PWR	826	720	100.0	616,165	103.6	Shutdown due to periodic inspection. (1. Aug.-)
Takahama-2	PWR	826	0	0.0	0	0.0	
Takahama-3	PWR	870	720	100.0	648,373	103.5	
Takahama-4	PWR	870	720	100.0	649,348	103.7	
Ohi-1	PWR	1175	720	100.0	840,712	99.4	
Ohi-2	PWR	1175	720	100.0	845,568	99.9	
Ohi-3	PWR	1180	720	100.0	862,515	101.5	
Ohi-4	PWR	1180	720	100.0	863,375	101.6	
Shimane-1	BWR	460	385	53.5	175,948	53.1	Shutdown due to periodic inspection. (17. Sep.-)
Shimane-2	BWR	820	720	100.0	589,140	99.8	
Ikata-1	PWR	566	720	100.0	409,262	100.4	Shutdown due to periodic inspection. (19. Sep.-)
Ikata-2	PWR	566	720	100.0	409,907	100.6	
Ikata-3	PWR	890	432	60.0	397,107	62.0	
Genkai-1	PWR	559	714	99.2	402,081	99.9	Shutdown due to periodic inspection. (30. Sep.-)
Genkai-2	PWR	559	720	100.0	411,018	102.1	
Genkai-3	PWR	1180	720	100.0	865,217	101.8	
Genkai-4	PWR	1180	720	100.0	857,944	101.0	
Sendai-1	PWR	890	720	100.0	642,952	100.3	
Sendai-2	PWR	890	11	1.5	1,918	0.3	Shutdown due to periodic inspection. (4. Aug.-30. Sep.)
Total/Average (Previous Month)		45742 (45742)	23,270 (24,639)	62.2 (63.7)	20,566,215 (21,536,950)	62.4 (63.3)	