

# Operating Records of Nuclear Power Plants in October

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	744	100.0	818,840	100.1	Shutdown due to periodic inspection. (5. Sep.-29. Oct.)
Tsuruga-1	BWR	357	744	100.0	268,008	100.9	
Tsuruga-2	PWR	1160	74	9.9	39,263	4.5	
Tomari-1	PWR	579	240	32.3	138,714	32.2	Shutdown due to inspection of a regenerative heat exchanger. (11. Oct.-) Manual shutdown due to leakage at a regenerative heat exchanger piping. (10. Sep.-)
Tomari-2	PWR	579	0	0.0	0	0.0	
Onagawa-1	BWR	524	744	100.0	392,315	100.6	Shutdown due to periodic inspection. (22. May-)
Onagawa-2	BWR	825	0	0.0	0	0.0	
Onagawa-3	BWR	825	744	100.0	635,471	103.5	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002-)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar.-)
Fukushima I-3	BWR	784	744	100.0	583,296	100.0	Shutdown due to periodic inspection. (2. Dec. 2002-)
Fukushima I-4	BWR	784	0	0.0	0	0.0	
Fukushima I-5	BWR	784	744	100.0	583,249	100.0	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep.-)
Fukushima II-1	BWR	1100	744	100.0	823,620	100.6	Shutdown due to periodic inspection. (14. Apr.-) Shutdown due to periodic inspection. (10. Dec. 2002-) Shutdown due to periodic inspection. (1. Feb.-) Shutdown due to periodic inspection. (3. Sep. 2002-)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	
Fukushima II-3	BWR	1100	0	0.0	0	0.0	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar.-)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar.-)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002-)
Kashiwazaki Kariwa-4	BWR	1100	744	100.0	828,950	101.3	Shutdown due to periodic inspection. (1. Mar.-) Shutdown due to periodic inspection. (23. Sep.-)
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	
Kashiwazaki Kariwa-6	ABWR	1356	744	100.0	1,041,504	103.2	
Kashiwazaki Kariwa-7	ABWR	1356	0	0.0	0	0.0	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002-)
Hamaoka-2	BWR	840	744	100.0	622,369	99.6	Shutdown due to periodic inspection. (20. Feb.-28. Oct.)
Hamaoka-3	BWR	1100	85	11.4	73,086	8.9	
Hamaoka-4	BWR	1137	744	100.0	845,921	100.0	
Shika-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Apr.-)
Mihama-1	PWR	340	744	100.0	258,434	102.2	Shutdown due to periodic inspection. (12. Sep.-)
Mihama-2	PWR	500	0	0.0	0	0.0	
Mihama-3	PWR	826	744	100.0	628,359	102.2	
Takahama-1	PWR	826	744	100.0	640,988	104.3	Shutdown due to periodic inspection. (1. Aug.-25. Oct.)
Takahama-2	PWR	826	160	21.6	106,360	17.3	
Takahama-3	PWR	870	744	100.0	672,192	103.8	
Takahama-4	PWR	870	744	100.0	673,266	104.0	
Ohi-1	PWR	1175	744	100.0	877,057	100.3	
Ohi-2	PWR	1175	744	100.0	884,301	101.2	
Ohi-3	PWR	1180	744	100.0	893,894	101.8	
Ohi-4	PWR	1180	744	100.0	896,400	102.1	
Shimane-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (17. Sep.-)
Shimane-2	BWR	820	744	100.0	610,080	100.0	
Ikata-1	PWR	566	744	100.0	424,598	100.8	Shutdown due to periodic inspection. (19. Sep.-)
Ikata-2	PWR	566	744	100.0	434,906	103.3	
Ikata-3	PWR	890	0	0.0	0	0.0	
Genkai-1	PWR	559	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep.-)
Genkai-2	PWR	559	744	100.0	427,629	102.8	
Genkai-3	PWR	1180	744	100.0	896,690	102.1	
Genkai-4	PWR	1180	744	100.0	889,652	101.3	
Sendai-1	PWR	890	744	100.0	667,985	100.9	
Sendai-2	PWR	890	744	100.0	618,874	93.5	
Total/Average (Previous Month)		45742 (45742)	21,391 (23,270)	55.3% (62.2)	19,196,271 (20,566,215)	56.4% (62.4)	