

Operating Records of Nuclear Power Plants in January

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	744	100.0	798,557	97.6	Manual shutdown due to reactor recirculation pump trouble. (28. Dec. 2003-3. Jan.)
Tsuruga-1	BWR	357	686	92.2	244,306	92.0	
Tsuruga-2	PWR	1160	744	100.0	876,847	101.6	
Tomari-1	PWR	579	744	100.0	440,481	102.3	
Tomari-2	PWR	579	744	100.0	443,421	102.9	
Onagawa-1	BWR	524	744	100.0	391,838	100.5	
Onagawa-2	BWR	825	744	100.0	622,574	101.4	
Onagawa-3	BWR	825	744	100.0	636,061	103.6	
Fukushima I-1	BWR	460	0	0.0	0	0.0	
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar. 2003~)
Fukushima I-3	BWR	784	744	100.0	587,671	100.8	
Fukushima I-4	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (2. Dec. 2002~)
Fukushima I-5	BWR	784	744	100.0	583,881	100.1	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep. 2003~)
Fukushima II-1	BWR	1100	744	100.0	826,139	100.9	
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr. 2003~)
Fukushima II-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Dec. 2002~)
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003~)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002~)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003~)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002~)
Kashiwazaki Kariwa-4	BWR	1100	744	100.0	831,970	101.7	
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Mar. 2003~)
Kashiwazaki Kariwa-6	ABWR	1356	744	100.0	1,047,728	103.9	
Kashiwazaki Kariwa-7	ABWR	1356	321	43.1	374,702	37.1	Shutdown due to periodic inspection. (23. Sep. 2003~19. Jan.)
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002~)
Hamaoka-2	BWR	840	744	100.0	617,122	98.7	
Hamaoka-3	BWR	1100	744	100.0	833,210	101.8	
Hamaoka-4	BWR	1137	744	100.0	852,243	100.7	
Shika-1	BWR	540	744	100.0	411,472	102.4	
Mihama-1	PWR	340	313	42.1	108,070	42.7	Shutdown due to periodic inspection. (14. Jan.~)
Mihama-2	PWR	500	744	100.0	378,290	101.7	
Mihama-3	PWR	826	744	100.0	641,398	104.4	
Takahama-1	PWR	826	744	100.0	642,731	104.6	
Takahama-2	PWR	826	744	100.0	641,300	104.4	
Takahama-3	PWR	870	0	0.0	0	0.0	Shutdown due to periodic inspection. (18. Dec. 2003~)
Takahama-4	PWR	870	744	100.0	673,283	104.0	
Ohi-1	PWR	1175	744	100.0	884,112	101.1	
Ohi-2	PWR	1175	744	100.0	895,138	102.4	
Ohi-3	PWR	1180	744	100.0	893,469	101.8	
Ohi-4	PWR	1180	744	100.0	899,417	102.4	
Shimane-1	BWR	460	744	100.0	349,716	102.2	
Shimane-2	BWR	820	744	100.0	614,226	100.7	
Ikata-1	PWR	566	744	100.0	431,260	102.4	
Ikata-2	PWR	566	744	100.0	432,036	102.6	
Ikata-3	PWR	890	744	100.0	690,832	104.3	
Genkai-1	PWR	559	744	100.0	427,871	102.9	
Genkai-2	PWR	559	744	100.0	431,234	103.7	
Genkai-3	PWR	1180	744	100.0	898,147	102.3	
Genkai-4	PWR	1180	0	0.0	0	0.0	Shutdown due to periodic inspection. (18. Dec. 2003~)
Sendai-1	PWR	890	744	100.0	669,449	101.1	
Sendai-2	PWR	890	744	100.0	674,840	101.9	
Total/Average (Previous Month)		45742 (45742)	27,360 (25,936)	70.7% (67.0)	23,697,042 (22,603,873)	69.6% (66.4)	