

# Operating Records of Nuclear Power Plants in February

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb.-)
Tsuruga-1	BWR	357	696	100.0	250,974	101.0	
Tsuruga-2	PWR	1160	696	100.0	820,232	101.6	
Tomari-1	PWR	579	696	100.0	412,285	102.3	
Tomari-2	PWR	579	696	100.0	414,956	103.0	
Onagawa-1	BWR	524	696	100.0	366,643	100.5	
Onagawa-2	BWR	825	696	100.0	582,352	101.4	
Onagawa-3	BWR	825	696	100.0	594,847	103.6	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002~)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar. 2003~)
Fukushima I-3	BWR	784	696	100.0	549,087	100.6	Shutdown due to periodic inspection. (2. Dec. 2002~)
Fukushima I-4	BWR	784	0	0.0	0	0.0	
Fukushima I-5	BWR	784	696	100.0	546,146	100.1	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep. 2003~)
Fukushima II-1	BWR	1100	696	100.0	667,600	87.2	Shutdown due to periodic inspection. (14. Apr. 2003~)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	
Fukushima II-3	BWR	1100	0	0.0	0	0.0	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003~)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002~)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003~)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002~)
Kashiwazaki Kariwa-4	BWR	1100	696	100.0	775,810	101.3	Shutdown due to periodic inspection. (1. Mar. 2003~)
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	
Kashiwazaki Kariwa-6	ABWR	1356	696	100.0	953,622	101.0	
Kashiwazaki Kariwa-7	ABWR	1356	696	100.0	974,708	103.3	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002~)
Hamaoka-2	BWR	840	486	69.8	370,785	63.4	Shutdown due to periodic inspection. (21. Feb.-)
Hamaoka-3	BWR	1100	696	100.0	778,960	101.7	
Hamaoka-4	BWR	1137	696	100.0	797,445	100.8	
Shika-1	BWR	540	696	100.0	384,343	102.3	
Mihama-1	PWR	340	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Jan.-)
Mihama-2	PWR	500	696	100.0	353,158	101.5	
Mihama-3	PWR	826	696	100.0	600,236	104.4	
Takahama-1	PWR	826	696	100.0	601,301	104.6	
Takahama-2	PWR	826	696	100.0	599,862	104.3	Shutdown due to periodic inspection. (18. Dec. 2003~)
Takahama-3	PWR	870	0	0.0	0	0.0	
Takahama-4	PWR	870	696	100.0	628,782	103.8	
Ohi-1	PWR	1175	696	100.0	827,615	101.2	Shutdown due to periodic inspection. (9. Feb.-)
Ohi-2	PWR	1175	192	27.6	226,334	27.7	
Ohi-3	PWR	1180	696	100.0	835,465	101.7	
Ohi-4	PWR	1180	696	100.0	841,562	102.5	
Shimane-1	BWR	460	696	100.0	328,734	102.7	
Shimane-2	BWR	820	696	100.0	577,554	101.2	
Ikata-1	PWR	566	696	100.0	403,777	102.5	
Ikata-2	PWR	566	696	100.0	404,346	102.6	
Ikata-3	PWR	890	696	100.0	646,769	104.4	
Genkai-1	PWR	559	696	100.0	400,105	102.8	Shutdown due to periodic inspection. (18. Dec. 2003~19. Feb.)
Genkai-2	PWR	559	696	100.0	403,411	103.7	
Genkai-3	PWR	1180	696	100.0	837,887	102.0	
Genkai-4	PWR	1180	248	35.6	244,138	29.7	
Sendai-1	PWR	890	696	100.0	626,207	101.1	
Sendai-2	PWR	890	696	100.0	630,835	101.8	
Total/Average (Previous Month)		45742 (45742)	24,590 (27,360)	67.9% (70.7)	21,258,873 (23,697,042)	66.8% (69.6)	