

Operating Records of Nuclear Power Plants in March

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb.-)
Tsuruga-1	BWR	357	744	100.0	268,228	101.0	
Tsuruga-2	PWR	1160	744	100.0	877,583	101.7	
Tomari-1	PWR	579	744	100.0	441,005	102.4	Shutdown due to periodic inspection. (24. Mar.-)
Tomari-2	PWR	579	552	74.2	326,796	75.9	
Onagawa-1	BWR	524	744	100.0	392,964	100.8	
Onagawa-2	BWR	825	744	100.0	622,293	101.4	
Onagawa-3	BWR	825	744	100.0	635,413	103.5	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002~)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar. 2003~)
Fukushima I-3	BWR	784	744	100.0	587,540	100.7	Shutdown due to periodic inspection. (2. Dec. 2002~22. Mar.)
Fukushima I-4	BWR	784	250	33.6	167,978	28.8	
Fukushima I-5	BWR	784	744	100.0	583,671	100.1	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep. 2003~)
Fukushima II-1	BWR	1100	744	100.0	824,290	100.7	Shutdown due to periodic inspection. (14. Apr. 2003~)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	
Fukushima II-3	BWR	1100	628	84.4	667,430	81.6	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003~)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002~)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003~)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002~)
Kashiwazaki Kariwa-4	BWR	1100	744	100.0	831,740	101.6	Shutdown due to periodic inspection. (1. Mar. 2003~)
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	
Kashiwazaki Kariwa-6	ABWR	1356	744	100.0	1,029,484	102.0	
Kashiwazaki Kariwa-7	ABWR	1356	744	100.0	1,037,364	102.8	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002~)
Hamaoka-2	BWR	840	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Feb.-)
Hamaoka-3	BWR	1100	744	100.0	832,313	101.7	
Hamaoka-4	BWR	1137	744	100.0	851,934	100.7	
Shika-1	BWR	540	744	100.0	410,786	102.2	
Mihama-1	PWR	340	707	95.1	239,525	94.7	Shutdown due to periodic inspection. (14. Jan.-2. Mar.)
Mihama-2	PWR	500	744	100.0	377,939	101.6	
Mihama-3	PWR	826	744	100.0	642,014	104.5	
Takahama-1	PWR	826	744	100.0	643,831	104.8	Shutdown due to periodic inspection. (18. Dec. 2003~8. Mar.)
Takahama-2	PWR	826	744	100.0	640,467	104.2	
Takahama-3	PWR	870	565	76.0	487,272	75.3	
Takahama-4	PWR	870	744	100.0	675,008	104.3	Shutdown due to periodic inspection. (9. Feb.-24. Mar.)
Ohi-1	PWR	1175	744	100.0	884,693	101.2	
Ohi-2	PWR	1175	181	24.3	189,745	21.7	
Ohi-3	PWR	1180	744	100.0	892,588	101.7	
Ohi-4	PWR	1180	744	100.0	899,438	102.5	
Shimane-1	BWR	460	744	100.0	350,828	102.5	Manual shutdown due to recirculation pump trouble. (17. Mar.-)
Shimane-2	BWR	820	410	55.1	336,525	55.2	
Ikata-1	PWR	566	744	100.0	431,829	102.5	
Ikata-2	PWR	566	744	100.0	432,047	102.6	
Ikata-3	PWR	890	744	100.0	690,659	104.3	
Genkai-1	PWR	559	744	100.0	427,980	102.9	Shutdown due to periodic inspection. (14. Mar.-)
Genkai-2	PWR	559	330	44.4	188,489	45.3	
Genkai-3	PWR	1180	744	100.0	898,115	102.3	
Genkai-4	PWR	1180	744	100.0	889,907	101.4	
Sendai-1	PWR	890	744	100.0	669,433	101.1	
Sendai-2	PWR	890	744	100.0	674,702	101.9	
Total/Average (Previous Month)		45742 (45742)	27,432 (24,590)	70.9 (67.9)	23,951,846 (21,258,873)	70.4 (66.8)	