

# Operating Records of Nuclear Power Plants in April

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	123	17.1	112,628	14.2	Shutdown due to periodic inspection. (1. Feb.-26. Apr.)
Tsuruga-1	BWR	357	720	100.0	259,411	100.9	
Tsuruga-2	PWR	1160	720	100.0	853,105	102.1	
Tomari-1	PWR	579	720	100.0	427,164	102.5	Shutdown due to periodic inspection. (24. Mar.-)
Tomari-2	PWR	579	0	0.0	0	0.0	
Onagawa-1	BWR	524	720	100.0	380,582	100.9	
Onagawa-2	BWR	825	720	100.0	602,303	101.4	
Onagawa-3	BWR	825	720	100.0	615,221	103.6	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002~)
Fukushima I-2	BWR	784	602	83.6	394,905	70.0	Shutdown due to periodic inspection. (31. Mar. 2003~6. Apr.)
Fukushima I-3	BWR	784	720	100.0	568,000	100.6	
Fukushima I-4	BWR	784	720	100.0	563,272	99.8	
Fukushima I-5	BWR	784	720	100.0	564,519	100.0	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep. 2003~)
Fukushima II-1	BWR	1100	720	100.0	797,370	100.7	
Fukushima II-2	BWR	1100	0	0.0	0	0.0	
Fukushima II-3	BWR	1100	720	100.0	799,000	100.9	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003~)
Kashiwazaki Kariwa-1	BWR	1100	561	77.9	573,740	72.4	Shutdown due to periodic inspection. (3. Sep. 2002~8. Apr.)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003~)
Kashiwazaki Kariwa-3	BWR	1100	304	42.2	293,030	37.0	Shutdown due to periodic inspection. (10. Aug. 2002~18. Apr.)
Kashiwazaki Kariwa-4	BWR	1100	720	100.0	804,430	101.6	
Kashiwazaki Kariwa-5	BWR	1100	11	1.6	1,960	0.2	
Kashiwazaki Kariwa-6	ABWR	1356	720	100.0	1,001,788	102.6	
Kashiwazaki Kariwa-7	ABWR	1356	720	100.0	1,006,184	103.1	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002~)
Hamaoka-2	BWR	840	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Feb.-)
Hamaoka-3	BWR	1100	720	100.0	802,877	101.4	
Hamaoka-4	BWR	1137	720	100.0	823,129	100.5	
Shika-1	BWR	540	720	100.0	397,404	102.2	
Mihama-1	PWR	340	720	100.0	253,996	103.8	
Mihama-2	PWR	500	720	100.0	365,237	101.5	
Mihama-3	PWR	826	720	100.0	621,004	104.4	
Takahama-1	PWR	826	241	33.5	204,984	34.5	Shutdown due to periodic inspection. (11. Apr.-)
Takahama-2	PWR	826	720	100.0	619,938	104.2	
Takahama-3	PWR	870	720	100.0	647,643	103.4	
Takahama-4	PWR	870	720	100.0	651,756	104.0	
Ohi-1	PWR	1175	720	100.0	855,935	101.2	
Ohi-2	PWR	1175	720	100.0	867,103	102.5	
Ohi-3	PWR	1180	456	63.3	542,922	63.9	
Ohi-4	PWR	1180	720	100.0	869,831	102.4	
Shimane-1	BWR	460	720	100.0	339,148	102.4	
Shimane-2	BWR	820	255	35.4	201,701	34.2	
Ikata-1	PWR	566	720	100.0	417,515	102.5	Shutdown due to periodic inspection. (21. Apr.-)
Ikata-2	PWR	566	480	66.7	277,668	68.1	
Ikata-3	PWR	890	720	100.0	668,014	104.2	
Genkai-1	PWR	559	720	100.0	413,904	102.8	
Genkai-2	PWR	559	0	0.0	0	0.0	
Genkai-3	PWR	1180	313	43.5	374,522	44.1	Shutdown due to periodic inspection. (14. Apr.-)
Genkai-4	PWR	1180	720	100.0	860,659	101.3	
Sendai-1	PWR	890	720	100.0	647,533	101.1	
Sendai-2	PWR	890	720	100.0	652,723	101.9	
Total/Average (Previous Month)		45742 (45742)	27,106 (27,432)	72.4% (70.9)	23,995,758 (23,951,846)	72.9% (70.4)	