

Operating Records of Nuclear Power Plants in May

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	744	100.0	828,862	101.3	
Tsuruga-1	BWR	357	744	100.0	268,013	100.9	
Tsuruga-2	PWR	1160	744	100.0	881,262	102.1	
Tomari-1	PWR	579	744	100.0	441,950	102.6	Shutdown due to periodic inspection. (24. Mar.-)
Tomari-2	PWR	579	0	0.0	0	0.0	
Onagawa-1	BWR	524	744	100.0	393,230	100.9	
Onagawa-2	BWR	825	744	100.0	622,014	101.3	
Onagawa-3	BWR	825	744	100.0	625,788	102.0	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002-)
Fukushima I-2	BWR	784	744	100.0	583,296	100.0	
Fukushima I-3	BWR	784	744	100.0	586,782	100.6	
Fukushima I-4	BWR	784	744	100.0	583,215	100.0	
Fukushima I-5	BWR	784	744	100.0	583,397	100.0	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	
Fukushima II-1	BWR	1100	744	100.0	823,110	100.6	Shutdown due to periodic inspection. (30. Sep. 2003-)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr. 2003-)
Fukushima II-3	BWR	1100	744	100.0	825,330	100.8	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003-)
Kashiwazaki Kariwa-1	BWR	1100	744	100.0	832,470	101.7	
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003-)
Kashiwazaki Kariwa-3	BWR	1100	744	100.0	830,820	101.5	
Kashiwazaki Kariwa-4	BWR	1100	744	100.0	830,940	101.5	
Kashiwazaki Kariwa-5	BWR	1100	744	100.0	675,690	82.6	
Kashiwazaki Kariwa-6	ABWR	1356	744	100.0	1,044,096	103.5	
Kashiwazaki Kariwa-7	ABWR	1356	744	100.0	1,038,602	102.9	
Hamaoka-1	BWR	540	0	0.0	0	0.0	
Hamaoka-2	BWR	840	0	0.0	0	0.0	
Hamaoka-3	BWR	1100	744	100.0	829,068	101.3	Shutdown due to periodic inspection. (21. Feb.-)
Hamaoka-4	BWR	1137	744	100.0	849,886	100.5	
Shika-1	BWR	540	744	100.0	409,950	102.0	
Mihama-1	PWR	340	744	100.0	260,158	102.8	Shutdown due to periodic inspection. (11. Apr.-)
Mihama-2	PWR	500	744	100.0	377,235	101.4	
Mihama-3	PWR	826	744	100.0	636,681	103.6	
Takahama-1	PWR	826	0	0.0	0	0.0	
Takahama-2	PWR	826	744	100.0	640,230	104.2	
Takahama-3	PWR	870	744	100.0	667,661	103.1	
Takahama-4	PWR	870	744	100.0	672,565	103.9	
Ohi-1	PWR	1175	744	100.0	880,997	100.8	Shutdown due to periodic inspection. (20. Apr.-)
Ohi-2	PWR	1175	744	100.0	894,614	102.3	
Ohi-3	PWR	1180	0	0.0	0	0.0	
Ohi-4	PWR	1180	744	100.0	897,666	102.2	
Shimane-1	BWR	460	744	100.0	348,851	101.9	
Shimane-2	BWR	820	744	100.0	613,877	100.6	
Ikata-1	PWR	566	744	100.0	423,253	100.5	Shutdown due to periodic inspection. (21. Apr.-)
Ikata-2	PWR	566	0	0.0	0	0.0	
Ikata-3	PWR	890	744	100.0	690,536	104.3	
Genkai-1	PWR	559	744	100.0	426,149	102.5	Shutdown due to periodic inspection. (14. Mar.-23. May.)
Genkai-2	PWR	559	203	27.3	86,390	20.8	
Genkai-3	PWR	1180	0	0.0	0	0.0	
Genkai-4	PWR	1180	744	100.0	889,329	101.3	
Sendai-1	PWR	890	744	100.0	669,188	101.1	
Sendai-2	PWR	890	744	100.0	674,847	101.9	
Sendai-3	PWR	890	744	100.0	674,847	101.9	
Total/Average (Previous Month)		45742 (45742)	29,219 (27,106)	75.5% (72.4)	26,137,998 (23,995,758)	76.8% (72.9)	