

Operating Records of Nuclear Power Plants in June

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	720	100.0	803,133	101.4	Automatic shutdown due to turbine trouble. (8-23. Jun.)
Tsuruga-1	BWR	357	370	51.3	128,020	49.8	
Tsuruga-2	PWR	1160	720	100.0	850,962	101.9	
Tomari-1	PWR	579	720	100.0	427,360	102.5	Shutdown due to periodic inspection. (24. Mar.-10. Jun.)
Tomari-2	PWR	579	491	68.2	270,536	64.9	
Onagawa-1	BWR	524	720	100.0	380,370	100.8	Shutdown due to periodic inspection. (10. Jun.-)
Onagawa-2	BWR	825	720	100.0	601,634	101.3	
Onagawa-3	BWR	825	217	30.1	166,321	28.0	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002-)
Fukushima I-2	BWR	784	720	100.0	564,480	100.0	
Fukushima I-3	BWR	784	720	100.0	567,361	100.5	
Fukushima I-4	BWR	784	720	100.0	562,914	99.7	
Fukushima I-5	BWR	784	720	100.0	564,714	100.0	
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30. Sep. 2003-)
Fukushima II-1	BWR	1100	720	100.0	796,810	100.6	
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr. 2003-)
Fukushima II-3	BWR	1100	720	100.0	798,620	100.8	
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb. 2003-)
Kashiwazaki Kariwa-1	BWR	1100	720	100.0	734,920	92.8	
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar. 2003-)
Kashiwazaki Kariwa-3	BWR	1100	720	100.0	802,600	101.3	
Kashiwazaki Kariwa-4	BWR	1100	720	100.0	802,550	101.3	
Kashiwazaki Kariwa-5	BWR	1100	720	100.0	806,260	101.8	
Kashiwazaki Kariwa-6	ABWR	1356	720	100.0	1,005,038	102.9	
Kashiwazaki Kariwa-7	ABWR	1356	720	100.0	995,970	102.0	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002-)
Hamaoka-2	BWR	840	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Feb.-)
Hamaoka-3	BWR	1100	720	100.0	800,075	101.0	
Hamaoka-4	BWR	1137	720	100.0	820,325	100.2	
Shika-1	BWR	540	720	100.0	363,101	93.4	
Mihama-1	PWR	340	720	100.0	247,992	101.3	
Mihama-2	PWR	500	720	100.0	360,334	100.1	
Mihama-3	PWR	826	720	100.0	608,287	102.3	
Takahama-1	PWR	826	321	44.5	254,310	42.8	Shutdown due to periodic inspection. (11. Apr.-17. Jun.)
Takahama-2	PWR	826	720	100.0	616,805	103.7	
Takahama-3	PWR	870	720	100.0	644,533	102.9	
Takahama-4	PWR	870	720	100.0	649,026	103.6	
Ohi-1	PWR	1175	72	10.0	79,978	9.5	Shutdown due to periodic inspection. (4. Jun.-)
Ohi-2	PWR	1175	720	100.0	859,074	101.5	
Ohi-3	PWR	1180	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Apr.-)
Ohi-4	PWR	1180	720	100.0	868,210	102.2	
Shimane-1	BWR	460	720	100.0	337,842	102.0	
Shimane-2	BWR	820	720	100.0	591,305	100.2	
Ikata-1	PWR	566	720	100.0	414,647	101.7	Shutdown due to periodic inspection. (21. Apr.-)
Ikata-2	PWR	566	0	0.0	0	0.0	
Ikata-3	PWR	890	720	100.0	668,017	104.2	
Genkai-1	PWR	559	720	100.0	412,546	102.5	Shutdown due to periodic inspection. (14. Apr.-24. Jun.)
Genkai-2	PWR	559	720	100.0	413,530	102.7	
Genkai-3	PWR	1180	152	21.0	129,457	15.2	
Genkai-4	PWR	1180	720	100.0	859,500	101.2	
Sendai-1	PWR	890	720	100.0	645,789	100.8	
Sendai-2	PWR	890	720	100.0	651,329	101.6	
Total/Average (Previous Month)		45742 (45742)	28,263 (29,219)	75.5% (75.5)	24,926,585 (26,137,998)	75.7% (76.8)	