

Operating Records of Nuclear Power Plants in August

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks	
			Operating hours [h]	[%]	Generated output [MWh]	[%]		
Tokai-Daini (II)	BWR	1100	744	100.0	827,844	101.2		
Tsuruga-1	BWR	357	744	100.0	264,465	99.6		
Tsuruga-2	PWR	1160	744	100.0	874,113	101.3		
Tomari-1	PWR	579	312	41.9	180,519	41.9	Shutdown due to periodic inspection. (14.Aug.-)	
Tomari-2	PWR	579	744	100.0	437,719	101.6		
Onagawa-1	BWR	524	744	100.0	391,731	100.5	Shutdown due to periodic inspection. (10.Jun.-) Turbine test operation. (28-29.Aug.)	
Onagawa-2	BWR	825	744	100.0	619,673	101.0		
Onagawa-3	BWR	825	8	1.1	981	0.2		
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20.Nov.2002-)	
Fukushima I-2	BWR	784	744	100.0	583,289	100.0		
Fukushima I-3	BWR	784	120	16.1	91,146	15.6	Planned shutdown. (6-8.Aug.) Shutdown due to periodic inspection. (9.Aug.-)	
Fukushima I-4	BWR	784	744	100.0	583,289	100.0		
Fukushima I-5	BWR	784	744	100.0	581,947	99.8	Shutdown due to periodic inspection. (30.Sep.2003-)	
Fukushima I-6	BWR	1100	0	0.0	0	0.0		
Fukushima II-1	BWR	1100	744	100.0	817,010	99.8	Shutdown due to periodic inspection. (14.Apr.2003-29.Aug.)	
Fukushima II-2	BWR	1100	76	10.2	57,479	7.0		
Fukushima II-3	BWR	1100	744	100.0	821,500	100.4	Shutdown due to periodic inspection. (1.Feb.2003-)	
Fukushima II-4	BWR	1100	0	0.0	0	0.0		
Kashiwazaki Kariwa-1	BWR	1100	744	100.0	826,740	101.0	Shutdown due to periodic inspection. (7.Aug.-)	
Kashiwazaki Kariwa-2	BWR	1100	744	100.0	825,140	100.8		
Kashiwazaki Kariwa-3	BWR	1100	744	100.0	823,540	100.6	Shutdown due to periodic inspection. (10.Jul.-)	
Kashiwazaki Kariwa-4	BWR	1100	156	21.0	164,470	20.1		
Kashiwazaki Kariwa-5	BWR	1100	744	100.0	825,890	100.9	Shutdown due to periodic inspection. (10.Jul.-)	
Kashiwazaki Kariwa-6	ABWR	1356	0	0.0	0	0.0		
Kashiwazaki Kariwa-7	ABWR	1356	744	100.0	1,026,108	101.7		
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26.Apr.2002-)	
Hamaoka-2	BWR	840	0	0.0	0	0.0		
Hamaoka-3	BWR	1100	744	100.0	823,187	100.6	Shutdown due to periodic inspection. (21.Feb.-)	
Hamaoka-4	BWR	1137	744	100.0	843,877	99.8		
Shika-1	BWR	540	744	100.0	403,393	100.4		
Mihama-1	PWR	340	744	100.0	252,156	99.7	Shutdown due to urgent safety inspection. (13.Aug.-)	
Mihama-2	PWR	500	311	41.8	150,148	40.4		
Mihama-3	PWR	826	207	27.9	172,208	28.0	Automatic shutdown due to secondary piping trouble. (9-14.Aug.) Shutdown due to periodic inspection. (14.Aug.-)	
Takahama-1	PWR	826	744	100.0	635,016	103.3		
Takahama-2	PWR	826	311	41.8	259,999	42.3	Shutdown due to urgent safety inspection. (13.Aug.-)	
Takahama-3	PWR	870	435	58.4	384,666	59.4		
Takahama-4	PWR	870	239	32.1	211,573	32.7	Shutdown due to periodic inspection. (10.Aug.-)	
Ohi-1	PWR	1175	744	100.0	853,464	97.6		
Ohi-2	PWR	1175	744	100.0	875,619	100.2	Shutdown due to periodic inspection. (20.Apr.-)	
Ohi-3	PWR	1180	0	0.0	0	0.0		
Ohi-4	PWR	1180	311	41.7	367,755	41.9	Shutdown due to urgent safety inspection. (13.Aug.-)	
Shimane-1	BWR	460	744	100.0	346,056	101.1		
Shimane-2	BWR	820	744	100.0	605,954	99.3		
Ikata-1	PWR	566	744	100.0	423,527	100.6		
Ikata-2	PWR	566	744	100.0	418,628	99.4		
Ikata-3	PWR	890	744	100.0	686,384	103.7		
Genkai-1	PWR	559	744	100.0	422,060	101.5	Shutdown due to periodic inspection. (13.Aug.-)	
Genkai-2	PWR	559	744	100.0	423,652	101.9		
Genkai-3	PWR	1180	744	100.0	892,943	101.7		
Genkai-4	PWR	1180	744	100.0	887,338	101.1		
Sendai-1	PWR	890	289	38.8	255,529	38.6		
Sendai-2	PWR	890	744	100.0	669,450	101.1		
Total/Average (Previous Month)		45742 (45742)	27,327 (30,983)	70.6% (80.1)	23,889,175 (26,894,190)	70.2% (79.0)		