

Operating Records of Nuclear Power Plants in October

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	744	100.0	829,975	101.4	Shutdown due to periodic inspection. (18.Sep.-27.Oct)
Tsuruga-1	BWR	357	117	15.8	36,404	13.7	
Tsuruga-2	PWR	1160	744	100.0	876,193	101.5	
Tomari-1	PWR	579	0	0.0	0	0.0	Shutdown due to periodic inspection. (14.Aug.-)
Tomari-2	PWR	579	744	100.0	441,450	102.5	
Onagawa-1	BWR	524	0	0.0	0	0.0	Shutdown due to periodic inspection. (8.Sep.-)
Onagawa-2	BWR	825	744	100.0	620,203	101.0	
Onagawa-3	BWR	825	744	100.0	634,040	103.3	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20.Nov.2002~)
Fukushima I-2	BWR	784	0	0.0	0	0.0	
Fukushima I-3	BWR	784	0	0.0	0	0.0	Manual Shutdown due to recirculation pump trouble. (29.Sep.-)
Fukushima I-4	BWR	784	744	100.0	583,102	100.0	
Fukushima I-5	BWR	784	514	69.0	386,925	66.3	Planned shutdown (13-22.Oct.)
Fukushima I-6	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (30.Sep.2003~)
Fukushima II-1	BWR	1100	0	0.0	0	0.0	
Fukushima II-2	BWR	1100	744	100.0	825,130	100.8	Shutdown due to periodic inspection. (29.Sep.-)
Fukushima II-3	BWR	1100	744	100.0	822,880	100.5	
Fukushima II-4	BWR	1100	24	3.2	4,860	0.6	Shutdown due to periodic inspection. (1.Feb.2003~)
Kashiwazaki Kariwa-1	BWR	1100	744	100.0	832,510	101.7	
Kashiwazaki Kariwa-2	BWR	1100	744	100.0	831,540	101.6	Shutdown due to periodic inspection. (7.Aug.-)
Kashiwazaki Kariwa-3	BWR	1100	744	100.0	828,570	101.2	
Kashiwazaki Kariwa-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (7.Aug.-)
Kashiwazaki Kariwa-5	BWR	1100	744	100.0	831,780	101.6	
Kashiwazaki Kariwa-6	ABWR	1356	395	53.0	510,654	50.6	Shutdown due to periodic inspection. (10.Jul.-15.Oct.)
Kashiwazaki Kariwa-7	ABWR	1356	744	100.0	1,028,576	102.0	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26.Apr.2002~)
Hamaoka-2	BWR	840	0	0.0	0	0.0	
Hamaoka-3	BWR	1100	744	100.0	825,303	100.8	Shutdown due to periodic inspection. (21.Feb.-)
Hamaoka-4	BWR	1137	0	0.0	0	0.0	
Shika-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (11.Sep.-)
Mihama-1	PWR	340	0	0.0	0	0.0	Shutdown due to urgent safety inspection. (5.Sep.-)
Mihama-2	PWR	500	0	0.0	0	0.0	
Mihama-3	PWR	826	0	0.0	0	0.0	Shutdown due to urgent safety inspection. (13.Aug.-)
Takahama-1	PWR	826	744	100.0	639,840	104.1	
Takahama-2	PWR	826	744	100.0	602,100	98.0	Shutdown due to periodic inspection. (14.Aug.-)
Takahama-3	PWR	870	744	100.0	663,964	102.6	
Takahama-4	PWR	870	82	11.0	50,012	7.7	Shutdown due to periodic inspection. (10.Aug.-28.Oct.)
Ohi-1	PWR	1175	369	49.6	415,856	47.6	
Ohi-2	PWR	1175	744	100.0	883,361	101.0	Shutdown due to urgent safety inspection. (24.Sep.-16.Oct.)
Ohi-3	PWR	1180	0	0.0	0	0.0	
Ohi-4	PWR	1180	0	0.0	0	0.0	Shutdown due to periodic inspection. (20.Apr.-)
Shimane-1	BWR	460	744	100.0	348,763	101.9	Shutdown due to periodic inspection. (7.Sep.-)
Shimane-2	BWR	820	0	0.0	0	0.0	
Ikata-1	PWR	566	0	0.0	0	0.0	Shutdown due to periodic inspection. (5.Sep.-)
Ikata-2	PWR	566	744	100.0	416,457	98.9	
Ikata-3	PWR	890	744	100.0	686,155	103.6	
Genkai-1	PWR	559	744	100.0	424,870	102.2	Shutdown due to periodic inspection. (13.Aug.-21.Oct.)
Genkai-2	PWR	559	744	100.0	427,186	102.7	
Genkai-3	PWR	1180	744	100.0	898,737	102.4	Shutdown due to periodic inspection. (13.Aug.-21.Oct.)
Genkai-4	PWR	1180	744	100.0	887,990	101.1	
Sendai-1	PWR	890	251	33.8	163,352	24.7	Shutdown due to periodic inspection. (13.Aug.-21.Oct.)
Sendai-2	PWR	890	744	100.0	671,732	101.4	
Total/Average (Previous Month)		45742 (45742)	21,096 (22,086)	54.5% (59.0)	19,930,470 (20,286,175)	58.6% (61.6)	