

わが国の原子力発電所の運転実績

(原産調べ)

| 発電所名 | 炉 型 | 認可出力 〔万kW〕 | 2003年4月 | | | | 備 考 |
|---------|-------|---------------|----------------|------------|-------------|------------|------------------------------------|
| | | | 発電電力量 〔MWh〕 | 利用率 〔%〕 | 稼働時間 〔時〕 | 稼働率 〔%〕 | |
| 東海 第二 | BWR | 110.0 | 794,563 | 100.3 | 720 | 100.0 | |
| 敦 賀 1 | " | 35.7 | 260,075 | 101.2 | 720 | 100.0 | |
| " 2 | PWR | 116.0 | 857,960 | 102.7 | 720 | 100.0 | |
| 泊 1 | " | 57.9 | 344,584 | 82.7 | 599 | 83.2 | 第11回定検中(4/25-) |
| " 2 | " | 57.9 | 427,029 | 102.4 | 720 | 100.0 | |
| 女 川 1 | BWR | 52.4 | 0 | 0.0 | 0 | 0.0 | 第15回定検中(02/9/8-) |
| " 2 | " | 82.5 | 593,674 | 99.9 | 720 | 100.0 | 制御棒パターン調整(4/9) |
| " 3 | " | 82.5 | 197,570 | 33.3 | 258 | 35.8 | 第1回定検中(2/24-) |
| 福島第一 1 | " | 46.0 | 0 | 0.0 | 0 | 0.0 | 第23回定検中(02/11/20-) |
| " 2 | " | 78.4 | 0 | 0.0 | 0 | 0.0 | 第20回定検中(3/31-) |
| " 3 | " | 78.4 | 0 | 0.0 | 0 | 0.0 | 第19回定検中(02/7/18-) |
| " 4 | " | 78.4 | 0 | 0.0 | 0 | 0.0 | 第19回定検中(02/12/2-) |
| " 5 | " | 78.4 | 0 | 0.0 | 0 | 0.0 | 第19回定検中(2/11-) |
| " 6 | " | 110.0 | 363,660 | 45.9 | 336 | 46.7 | 原子炉格納容器漏洩率検査のため中間停止(4/15-) |
| 福島第二 1 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第16回定検中(1/7-) |
| " 2 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 故障停止(02/9/3-4/13), 第15回定検中(4/14-) |
| " 3 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第12回定検中(02/12/10-) |
| " 4 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第12回定検中(2/1-) |
| 柏崎刈羽 1 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第13回定検中(02/9/3-) |
| " 2 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第10回定検中(3/10-) |
| " 3 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第7回定検中(02/8/10-) |
| " 4 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第7回定検中(1/7-) |
| " 5 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第10回定検中(3/1-) |
| " 6 | A BWR | 135.6 | 0 | 0.0 | 0 | 0.0 | 第5回定検中(1/27-) |
| " 7 | " | 135.6 | 0 | 0.0 | 0 | 0.0 | 格納容器漏洩率検査のため中間停止(3/29-) |
| 浜 岡 1 | BWR | 54.0 | 0 | 0.0 | 0 | 0.0 | 第19回定検中(02/4/26-) |
| " 2 | " | 84.0 | 604,764 | 100.0 | 720 | 100.0 | |
| " 3 | " | 110.0 | 0 | 0.0 | 0 | 0.0 | 第12回定検中(2/20-) |
| " 4 | " | 113.7 | 0 | 0.0 | 0 | 0.0 | 第7回定検中(02/9/4-) |
| 志 賀 1 | " | 54.0 | 262,781 | 67.6 | 480 | 66.7 | 第8回定検中(4/21-) |
| 美 浜 1 | PWR | 34.0 | 253,621 | 103.6 | 720 | 100.0 | |
| " 2 | " | 50.0 | 364,898 | 101.4 | 720 | 100.0 | |
| " 3 | " | 82.6 | 594,646 | 100.0 | 720 | 100.0 | |
| 高 浜 1 | " | 82.6 | 624,251 | 105.0 | 720 | 100.0 | |
| " 2 | " | 82.6 | 622,521 | 104.7 | 720 | 100.0 | |
| " 3 | " | 87.0 | 653,050 | 104.3 | 720 | 100.0 | |
| " 4 | " | 87.0 | 561,714 | 89.7 | 649 | 90.1 | 第14回定検中(4/28-) |
| 大 飯 1 | " | 117.5 | 361,832 | 42.8 | 312 | 43.3 | 第18回定検中(4/14-) |
| " 2 | " | 117.5 | 869,104 | 102.7 | 720 | 100.0 | |
| " 3 | " | 118.0 | 865,778 | 101.9 | 720 | 100.0 | |
| " 4 | " | 118.0 | 870,256 | 102.4 | 720 | 100.0 | |
| 島 根 1 | BWR | 46.0 | 331,199 | 100.0 | 720 | 100.0 | |
| " 2 | " | 82.0 | 273,268 | 46.3 | 337 | 46.8 | 第11回定検中(4/15-) |
| 伊 方 1 | PWR | 56.6 | 362,489 | 88.9 | 624 | 86.7 | 第21回定検中(4/27-) |
| " 2 | " | 56.6 | 375,987 | 92.3 | 719 | 99.9 | 第16回定検(1/27-4/1) |
| " 3 | " | 89.0 | 671,496 | 104.8 | 720 | 100.0 | |
| 玄 海 1 | " | 55.9 | 412,616 | 102.5 | 720 | 100.0 | |
| " 2 | " | 55.9 | 416,418 | 103.5 | 720 | 100.0 | |
| " 3 | " | 118.0 | 866,709 | 102.0 | 720 | 100.0 | |
| " 4 | " | 118.0 | 860,601 | 101.3 | 720 | 100.0 | |
| 川 内 1 | " | 89.0 | 408,436 | 63.7 | 457 | 63.5 | 第15回定検中(4/20-) |
| " 2 | " | 89.0 | 650,635 | 101.5 | 720 | 100.0 | |
| 小計または平均 | | 4,574.2 | 16,978,185 | 51.6% | 20,611 | 55.1% | |
| ()は前月 | | (4,590.7) | (20,085,196) | (59.0) | (23,438) | (60.6) | |
| 時間稼働率 | | | | | | 50.8 | |
| ()は前月 | | | | | | (58.2) | |